

STATEMENT OF WORK

Background: the U.S. Embassy Kyiv is requesting the procurement of ***7 pieces of fuel tanks for diesel-generators*** with next technical requirements:

Fuel volume - 200 liters.

Material - stainless steel, double-walled.



Item`s location - above ground.

Additional information: a tank should have the following parts and characteristics: a nozzle for refueling (standard), and a nozzle for connection to diesel generators; fuel drain pipe; connection for level sensors - 2 ea.; level sensor, connection for remote control sensor (matter to discussion after award), fuel pump: 9 liters / hour or higher; tanks must be calibrated. A detailed drawing for visual understanding is below.

NOTE: You can provide your drawing of your product. We kindly ask you to indicate in your Quota the period for the manufacture of the above products. The date of delivery of the products will be negotiated separately with the winner of this solicitation.

Warranty: Standard manufacturer or seller warranty in Ukraine is required for all items.

Specifications



↑A

